



Clio Area Fire Authority

3291 W. Vienna Rd
Clio, MI. 48420
Phone: 810-687-8506

Inspection Application for Mobile Food Vehicles

Name of Business Owner _____ Date of Birth ____/____/____

Driver's License Number: _____ State Issued: _____

Home Address _____

City _____ State _____ Zip Code _____

Business Name _____

Business Address _____

City _____ State _____ Zip _____

Telephone Number (____) (____) _____

This Vehicle has the Following Fuel and Cooking Operations

- | | | | |
|---|---|-------------------------------------|--------------------------------------|
| ☐ Propane (LPG) | ☐ Compressed Natural Gas (CNG) | ☐ Generator | ☐ Solar |
| ☐ Stove | ☐ Oven | ☐ Deep Fryer | ☐ Hood System |
| ☐ Automatic Fire Suppression | | | |

Email: _____ Website: _____

License Plate: _____

Vehicle Identification Number _____ Year Built _____

Vehicle Insurance Policy Number _____

Vehicle Insurance Provider _____

Address of Insurance Provider _____

City _____ State _____ Zip Code _____

Insurance Provider Telephone (____) _____

By signing below, I _____ affirm that all the above to be true and correct.

Further, I am the party responsible for all safe operations to be conducted in the Mobile Food Vehicle listed. I shall abide by all directions within the scope of the Fire Code for the Clio Area Fire Authority, the International Fire Code as adopted.



Clio Area Fire Authority

3291 W. Vienna Rd

Clio, MI. 48420

Phone: 810-687-8506

Mobile Food Vehicles Requirements for Food Trucks and Trailers:

1. Vehicles that produce grease laden vapors must have a Type 1 hood. Hoods shall be subject to cleaning and inspection.
2. Portable fire extinguishers shall be located in conspicuous locations where they will be readily accessible and immediately available for use. All employees working in the vehicle shall be trained in the proper use of a fire extinguishers. Fire extinguishers shall bear a current inspection tag validated within the past twelve months OR a receipt of purchase within the last 12 months shall be available for inspection.
 - a. Vehicles using a liquid or gas fuel source shall have a minimum 2A20BC fire extinguisher. Vehicles using a solid fuel source shall have a minimum of a 6L Class K fire extinguisher for solid fuel.
 - b. Vehicles that have a deep fat fryer shall have a 6L Class "K" rated fire extinguisher.
3. Vehicles using Liquefied Petroleum Gases for operations shall comply with International Fire Code as adopted.
4. Vehicle shall have a propane or natural gas leak detector.
5. Only rubber hose stamped "Approved for LP Gas" used from tank to the attached black pipe that is secured to vehicle shall be used to transport gas through vehicle to appliances. Copper piping shall NOT be used.
6. The main system shutoff valves located on or closest to the fuel tanks and sufficient to stop the supply of fuel from all fuel tanks must be clearly marked with the words "PROPANE SHUTOFF VALVE or NATURAL GAS SHUTOFF VALVE" permanently affixed to the outside of the vehicle in reflective decal material with letters 2" high at minimum.
7. A "No Smoking" sign next to or directly above the propane container and visible to the public.
8. Shall be equipped with a working carbon monoxide detector
9. All automatic fire extinguishing systems shall be inspected by a servicing company every 12 months and properly tagged.

Applicant Printed Name:_____

Applicant Signature:_____ **Date:**_____

PLEASE RETURN COMPLETED FORMS TO INFO@CLIOAREAFIRE.COM